



MISSOURI DEPARTMENT OF ELEMENTARY AND SECONDARY EDUCATION  
OFFICE OF CHILDHOOD - CHILD CARE COMPLIANCE

COMPLAINT INVESTIGATION OF  
SUBSTANTIATED STATUTE OR RULE VIOLATIONS

DATE OF REPORT  
5/1/2019

DVN  
002294333

FACILITY NAME

CHILDREN'S PLAYHOUSE AND LEARNING CENTER, LLC

FACILITY ADDRESS

1305 SANDERS ST

CITY

HARRISONVILLE

ZIP CODE

64701-3035

PHONE NUMBER

(816) 380-3880

COUNTY

CASS

ASSIGNED SPECIALIST

SNODGRASS, PENNY

RULE/STATUTE VIOLATION(S)

VIOLATION(S)

19 CSR 30-62.082 (2)(A)(6)

Walls, ceilings and floors shall be finished with material which can be cleaned easily and shall be free of splinters, cracks and chipping paint. Floor covering shall be in good condition. Lead-free paint shall be used for all painted surfaces.

CONCLUSION SUMMARY

Section for Child Care Regulation determined the above allegation to be substantiated. It was determined that Children's Playhouse and Learning Center, LLC violated licensing rules when a leak was detected but not repaired before a portion of the ceiling fell in the infant/toddler room while children were being cared for in the room.

On May 1, 2019 Child Care Facility Specialist (CCFS) Penny Snodgrass conducted an unannounced inspection to initiate the complaint investigation. During the inspection interviews were conducted with Director; Sara Combs and staff members Shania Holly Saylor and Stacy Hankins.

Based on interviews and observation this allegation is substantiated. Director, Sara Combs and staff members Stacy Hankins and Shania Holly Saylor all stated that the ceiling in the infant room had a water leak from the rain and that the plastered part of the ceiling fell in on Tuesday, April 30, 2019. CCFS Snodgrass observed an area of the ceiling in the infant room that measured approximately three (3) feet by two (2) feet where the plastered part of the ceiling was missing and the remaining part of the ceiling was peeling and wet.

CORRECTIVE MEASURES

CORRECTIVE MEASURE

The facility will pass a sanitation inspection by the Bureau of Environmental Health Services

COMPLETED (Y/N)

Yes

COMPLETED DATE

5/22/2019

CORRECTIVE MEASURE

The facility will have the ceiling repaired so that it is in good repair

COMPLETED (Y/N)

Yes

COMPLETED DATE

5/20/2019

DISPOSITION

SUBSTANTIATED

DISPOSITION DATE

6/14/2019

APPROVING SUPERVISOR

TAYLOR, WANDA ILENE