



**MISSOURI DEPARTMENT OF ELEMENTARY AND SECONDARY EDUCATION
OFFICE OF CHILDHOOD - CHILD CARE COMPLIANCE
COMPLAINT INVESTIGATION OF
SUBSTANTIATED STATUTE OR RULE VIOLATIONS**

DATE OF REPORT
12/22/2016

DVN
000513831

FACILITY NAME

MAGIC MOMENTS LEARNING CENTER, INC

FACILITY ADDRESS

8784 N BROADWAY

CITY

ST LOUIS

ZIP CODE

63147

PHONE NUMBER

(314) 867-2523

COUNTY

ST LOUIS CITY

ASSIGNED SPECIALIST

VIVIANO, KELLY

RULE/STATUTE VIOLATION(S)

VIOLATION(S)

19 CSR 30-62.082 (2)(A)(5)

The facility shall be dry, temperature controlled, well-ventilated and free of drafts. Children shall not be overheated or chilled. The temperature of the rooms shall be no less than sixty-eight degrees Fahrenheit (68F) and no more than eighty-five degrees Fahrenheit (85F) when measured two feet (2') from the floor.

CONCLUSION SUMMARY

Based on the investigation, the allegation that, on December 21, 2016, the rear toddler building had a temperature reading of 47 degrees F, is substantiated.

On January 3, 2017, Albert Walker stated that he had been keeping the heat off in the rear toddler room because he was unaware that he was suppose to keep it warm when the room wasn't being used for child care. He became aware of this requirement when the sanitation inspector visited his facility, on December 21, 2016. He has been keeping the temperature maintained in all the rooms since that inspection.

On January 3, 2017, Center Director Bonnie Walker stated that she was aware that the heat was turned off in the rear toddler room but she did this out of ignorance because she did not know that the facility needed to keep it warm when the room wasn't being used for child care. She became aware of this requirement when the sanitation inspector visited the facility and she has been keeping the temperature maintained in all the rooms since that inspection.

CORRECTIVE MEASURES

CORRECTIVE MEASURE

On January 3, 2017, both Bonnie and Albert Walker acknowledged that the temperatures have been maintained since they became aware of this requirement. At the January 3, 2017 investigation, temperatures were maintained within the required degrees.

COMPLETED (Y/N)

Yes

COMPLETED DATE

1/3/2017

DISPOSITION

SUBSTANTIATED

DISPOSITION DATE

3/4/2017

APPROVING SUPERVISOR

AHLEMEYER, CARON